EXIT AND EMERGENCY LIGHTING TEST RECORD

FACILITY: _____ YEAR: _____

ADDRESS: _____

Note: Monthly test - 30 second functional test.
Annual Test – 1 1/2 hour duration test.

Rev. 1-5-17

Unit #	Jan _____	Feb _____	Mar _____	Apr _____	May _____	June _____	July _____	Aug _____	Sept _____	Oct _____	Nov _____	Dec _____	1½ Hour Annual Test