

Procurement Division, 1000 N. Central Street, Suite 100, Knoxville, TN 37917

PROCUREMENT DIVISION ADDENDUM I **BID NUMBER 3515 HVAC REPLACEMENT, CONTROLS AND ELECTRICAL UPGRADES**

ADDENDUM DATE: January 26, 2024 **BUYER: Donnie Fawver**

BID OPENING DATE: February 7, 2024 2:00 PM PAGE: 2 (Two) Pages

QUESTIONS/ANSWERS:

QUESTION 1: Is there a date projected for work to be completed?

ANSWER 1: Yes, by July 15, 2024.

QUESTION 2: Can material by stored on site until work begins?

ANSWER 2: No, Contractor is responsible for storage prior to work beginning.

QUESTION 3: Underneath the Classroom Heat Pump schedule on page M4.1. Note 9 states all units with filler panel to extend to ceiling. Can Knox County provide the ceiling heights of the classrooms if this is a requirement.

ANSWER 3: The classroom ceiling heights are nine feet nine inches high (9'9"). The only variance is the cafeteria which is nine feet (9') due to an acoustical ceiling.

QUESTION 4: KCS requested the Bard units to be provided with a terminal strip. Note 10 under the schedule states each unit to be provided with BACnet communication. It is my understanding that the control vendor will be providing the BACnet controller for this project.

ANSWER 4: Correct, the controls vendor will be providing the BACnet controllers for the units. The Bard units need to be provided with a terminal strip to accommodate either control bidder.

Procurement Division, 1000 N. Central Street, Suite 100, Knoxville, TN 37917

Notes:

Be sure to acknowledge this Addendum 1 when submitting bid.

Bid Envelope Cover must be filled out completely with "NA" or "none required" if no subcontractor to be listed and attached to the outside of sealed envelope.

End of Addendum I

Donnie Fawyer II

Donnie Fawver, II **Senior Buver**

Knox County Government

This addendum is issued from the Knox County Procurement Division, Suite 100, 1000 North Central Street, Knoxville, TN 37917. The telephone number is (865) 215-5777 and the fax number is (865) 215-5778.